

Example Calculations
Evaluation for Fine Bubble Aeration System

AERATION SYSTEM DESIGN FOR PEAK LOADINGS

Revision Date
6/10/02 9:52

Red Valve Company, Inc.
700 NORTH BELL AVENUE
CARNEGIE, PA 15106-0548

PHONE (412) 279-0044
FAX (412) 279-5410



Red Valve Representative

Example Calculations
Evaluation for Fine Bubble Aeration System

Input Data & Design Parameters for Biological / Chemical Process Systems

Design Plant Flowrate	4,000,000	gpd	15,141.60	m3/day
Design COD influent concentration	800.0	mg/l		
Design COD effluent concentration	450.0	mg/l		
Design BOD influent concentration	240.0	mg/l		
Design BOD effluent concentration	20.0	mg/l		
Design NH4 influent concentration	35.0	mg/l		
Design NH4 effluent concentration	5.0	mg/l		
CLIENT INPUT VALUES				
Pre-Determined AOR Value to be Applied	12,000.0	lbs/day	5,443.2	kg/day
Pre-Determined Oxygen Uptake Rate to be Applied	0.000	mg/l/hr		
Process Design Values				
Lbs of Oxygen required per lb. Of BOD removed	1.10	lbs O2/lb BOD	0.499	kg O2/kg BOD
Lbs of Oxygen Required per lb. Of NH3 removed	3.80	lbs O2/lb BOD	1.724	kg O2/kg BOD
MLSS Concentration at Design	2300	mg/l		
Food to BioMass ratio F/M	0.20			
BIOLOGICAL PROCESS PARAMETERS				
Oxygen Transfer Efficiency Values				
Diffuser distance from bottom of tank	0.50	ft.	0.2	m
Diffuser Depth (Dp)	15.5	ft.	4.7	m
Site Barometric Pressure (Pa)	29.00	in Hg	14.24	psia
Barometric Pressure at Mean Sea Level (Pmsl)	29.92	in Hg	14.70	psia
Surface Oxygen Saturation at 20 C (Cs)	9.09	mg/l		
Surface Oxygen Saturation at Temp (Cst)	10.10	mg/l		
Submergence Saturation of Diffuser at Depth (Cd)	10.30	mg/l		
Dissolved Oxygen Level (DO)	2.00	mg/l		
Waste Water Temperature (T)	64.4	F	18.0	C
Alpha Factor	0.45			
Beta Factor	0.950			
Theta Factor	1.024			
Corrected Saturation at Temperature (Ccr)	11.4444	mg/l		
ENGINEER / PILOT DATA ADJUSTMENT FACTORS				
Blower Parameters for Horsepower Sizing				
Inlet Blower Air Temperature	100	F	37.7	C
Existing Airflow at design conditions	0	scfm		
Density of Air at Sea Level and 70F	0.075	lbs/ft^3		
Density of Air Correction factor	0.912			
Corrected Density of Air at Site Elevation & Temp	0.0684	lbs/ft^3		

Input Parameters for Post Aeration Systems

Solution Transfer Efficiency Factor		Range (1.10 - 1.40)
Influent Dissolved Oxygen Concentration		mg/l
Required Effluent Dissolved Oxygen Concentration		mg/l

Example Calculations
Evaluation for Fine Bubble Aeration System

US Units

RECTANGULAR TANK DIMENSIONS

US UNITS

Tank	Length feet	Width feet	Water Depth feet	Aeration Surface Area sq. ft.	Conical Bottom Volume cubic feet	Aeration Dimensional Volume cubic feet	Aeration Liquid Volume gallons	AOR Distribution Percentage
1	100.00	40.00	16.00	4,000		64,000	478,720	25%
2	100.00	40.00	16.00	4,000		64,000	478,720	25%
3	100.00	40.00	16.00	4,000		64,000	478,720	25%
4	100.00	40.00	16.00	4,000		64,000	478,720	25%

AOR PROPORTIONING

4 Number of Tanks

16,000 sq.ft.	256,000 cuft	1,914,880 gallons	100%
------------------	-----------------	----------------------	------

SI Units

SI UNITS

Tank	Length meters	Width meters	Depth meters	Aeration Surface Area sq. meters	Conical Bottom Volume meter^3	Aeration Dimensional Volume cubic meters	Aeration Liquid Volume liters	AOR Distribution Percentage
1	30.48	12.19	4.88	372	0	1,812	1,811,955	25%
2	30.48	12.19	4.88	372	0	1,812	1,811,955	25%
3	30.48	12.19	4.88	372	0	1,812	1,811,955	25%
4	30.48	12.19	4.88	372	0	1,812	1,811,955	25%

1,486 sq.m.	7,249 cu.m	7,247,821 L	100%
----------------	---------------	----------------	------

Example Calculations
Evaluation for Fine Bubble Aeration System

Reference Table
Oxygen Requirements for Biological Treatment Processes

REFERENCE TABLE

Carbonaceous BOD5 Removal

BOD / O2 RATIO

Biological Treatment Process Type	Process Parameters			Actual Oxygen Required (AOR) (1)			
	BOD Loading lbs. BOD per 1000 cu.ft. Tank Volume	Food to Biomass Ratio F / M	MLSS Conc. mg/l	Fine Bubble Diffusers lbs. O2 / lb. of BOD	Coarse Bubble Diffusers lbs. O2 / lb. of BOD	Mechanical Aeration lbs. O2 / lb. of BOD	Ten States Standards (2) lbs. O2 / lb. of BOD
Extended Aeration	10 to 25	0.05 to 0.15	1200 to 2500	1.10 to 0.75	1.30 to 0.85	1.50 to 1.00	1.50
Oxidation Ditch	5 to 30	0.05 to 0.30	800 to 2500	1.10 to 0.75	1.30 to 0.85	1.50 to 1.00	1.50
Single Stage Nitrification	5 to 20	0.10 to 0.25	800 to 2500	1.10 to 0.75	1.30 to 0.85	1.50 to 1.00	1.10
Sequencing Batch Reactor	5 to 50	0.05 to 0.45	800 to 5500	1.10 to 0.75	1.30 to 0.85	1.50 to 1.00	1.10
Plug Flow / Complete Mix	20 to 120	0.30 to 1.00	2500 to 5500	0.75 to 0.30	0.85 to 0.40	1.00 to 0.50	1.10
High Rate Aeration	100 to 1000	0.40 to 1.5	4500 to 10,000	0.75 to 0.30	0.85 to 0.40	1.00 to 0.50	1.10

Nitrification of Ammonia

NH3 / O2 RATIO

Biological Treatment Process Type	Process Parameters			Actual Oxygen Required (AOR) (1)			
	BOD Loading lbs. BOD per 1000 cu.ft. Tank Volume	Food to Biomass Ratio F / M	MLSS Conc. mg/l	Fine Bubble Diffusers lbs. O2 / lb. of TKN	Coarse Bubble Diffusers lbs. O2 / lb. of TKN	Mechanical Aeration lbs. O2 / lb. of TKN	Ten States Standards (2) lbs. O2 / lb. of TKN
Extended Aeration	10 to 25	0.05 to 0.15	1200 to 2500	3.80 to 4.00	4.20 to 4.40	4.50 to 4.60	4.60
Oxidation Ditch	5 to 30	0.05 to 0.30	800 to 2500	3.80 to 4.00	4.20 to 4.40	4.50 to 4.60	4.60
Single Stage Nitrification	5 to 20	0.10 to 0.25	800 to 2500	3.80 to 4.00	4.20 to 4.40	4.50 to 4.60	4.60
Sequencing Batch Reactor	5 to 50	0.05 to 0.45	800 to 5500	3.80 to 4.00	4.20 to 4.40	4.50 to 4.60	4.60
Plug Flow / Complete Mix	20 to 120	0.30 to 1.00	2500 to 5500	3.40 to 3.60	4.00 to 4.20	4.50 to 4.60	4.60
High Rate Aeration	100 to 1000	0.40 to 1.5	4500 to 10,000	3.40 to 3.60	4.00 to 4.20	4.50 to 4.60	4.60

1. AOR Ratio Values listed are typical operating values, a safety factor of 1.20 should be applied for blower capacity design.
2. Recommended value if treatability design data is unavailable for the application.

Example Calculations
Evaluation for Fine Bubble Aeration System

Check Aeration Tank Volume Required Based on Food to (Bio)Mass Ratio

BIOLOGICAL TREATMENT PROCESS

Design BOD to be removed =	<input type="text" value="7,339"/>	lbs/day	<input type="text" value="3,329.1"/>	kg/day
Applied Food to (Bio)Mass Ratio F/M =	<input type="text" value="0.20"/>		RELATIVE TO TYPE OF PROCESS	
BOD Loading =	<input type="text" value="28.67"/>	lbs. BOD / 1000 cu.ft. Tank Volume		
MLSS Mass =BOD / (F/M) =	<input type="text" value="36696.0"/>	lbs	<input type="text" value="16,645.31"/>	kg
Required MLSS Concentration =	<input type="text" value="2300"/>	mg/l		
Tank Volume Required = (MLSS Mass) / [(MLSS Conc.) x 8.34]				
Tank Liquid Volume Required =	<input type="text" value="1,913,043"/>	GAL	<input type="text" value="7,241,658"/>	L
Existing Tank Volume or Tank Volume Specified by Client =	<input type="text" value="1,914,880"/>	GAL	<input type="text" value="7,248,610"/>	L
TANK VOLUME AVAILABLE		TANK VOLUME REQUIRED		

Example Calculations
Evaluation for Fine Bubble Aeration System

Actual Oxygen Required (AOR)
Based on BOD, COD and NH3 Loading

BOD Influent Conc.
240 mg/l

BOD Effluent Conc.
20 mg/l

Plant Flow Capacity
4,000,000 GPD

Total Influent BOD Mass
8,006 lbs./day

Total Effluent BOD Mass
667 lbs./day

BOD / O2 RATIO

Total BOD mass to be removed	7,339 lbs./day	3,329 kg/day
Lbs. of Oxygen required per lb. of BOD removed	1.10 lbs.O2/lb BOD	0.499 kg.O2/lb BOD
Oxygen required for BOD removal	8,073 lbs./day	3,662 kg/day

NH3 Influent Conc.
35 mg/l

NH3 Effluent Conc.
5 mg/l

**MUNICIPAL /
FOOD PROCESSING
WASTEWATER**

NH3 / O2 RATIO

Total Influent NH3 Mass
1,168 lbs./day

Total Effluent NH3 Mass
166.8 lbs./day

Total NH3 mass to be removed	1,001 lbs./day	454 kg/day
Lbs. of Oxygen required per lb. of NH3 removed	3.80 lbs.O2/lb NH3	1.724 kgO2/lb NH3
Oxygen required for NH3 removal	3,803 lbs./day	1,725 kg/day

COD Influent Conc.
800 mg/l

COD Effluent Conc.
450 mg/l

**INDUSTRIAL
CHEMICAL
WASTEWATER**

Total Influent COD Mass
26,688 lbs./day

Total Effluent COD Mass
15,012 lbs./day

$$\text{Oxygen Demand} = (\text{Alpha} \times \text{COD} \times \text{R}) + (\text{Beta} \times (\text{COD} / \text{FM}))$$

Alpha = **0.40**
Beta = **0.10**
COD = **11,676**
R = **1**
FM = **0.20**

Alpha = Oxygen Utilization Coefficient for Synthesis, lb/lb
Beta = Oxygen Utilization Coefficient for Endogenous Respiration, lb/lb
COD = COD loading to Aeration Tank, lbs/day
R = % Reduction of COD
FM = Food to Biomass Ratio

COD / O2 RATIO

Total COD mass to be removed	11,676 lbs./day	5,296 kg/day
Oxygen Required for COD Removal	10,508 lbs/day	4,767 kg/day

Example Calculations Evaluation for Fine Bubble Aeration System
--

Selected - Actual Oxygen Required (AOR) Based on COD, BOD, NH3 and Uptake Rates
--

	Oxygen Uptake Rate	<input type="text" value="0"/>	mg/l/hr		
AOR1	AOR per Uptake Rate	<input type="text" value="0"/>	lbs./day	<input type="text" value="0"/>	kg/day
AOR2	AOR for BOD & NH3 removal	<input type="text" value="11,876"/>	lbs./day	<input type="text" value="5,387"/>	kg/day
AOR3	AOR for COD	<input type="text" value="10,508"/>	lbs./day	<input type="text" value="4,767"/>	kg/day
AOR4	AOR as Specified by Owner	<input type="text" value="12,000"/>	lbs./day	<input type="text" value="5,443"/>	kg./day
AOR5	AOR as Required by Digester	<input type="text" value="4,416"/>	lbs./day	<input type="text" value="2,003"/>	kg./day
	Selected AOR				
	(maximum of AOR1, AOR2, AOR3,AOR4 & AOR5)	<input type="text" value="12,000"/>	lbs./day	<input type="text" value="5,443"/>	kg/day
	AOR conversion	<input type="text" value="500.00"/>	lbs/hr (24 hr. day)	<input type="text" value="226.80"/>	kg/hr (24 hr. day)

**AOR: ACTUAL DISSOLVED OXYGEN REQUIRED
FOR BIOLOGICAL ORGANISMS TO REDUCE
THE MASS OF WASTE LOADING**

Example Calculations
Evaluation for Fine Bubble Aeration System

FINE BUBBLE DIFFUSER SYSTEM
Number of Fine Bubble Diffusers and Total Airflow Required

AOR = Actual Oxygen Transferred into wastewater solution
 SOTR = Oxygen transfer rate based on clean water

**CLEAN WATER
EQUIVALENT O₂**

Tank No.	AOR kg/hr	AOR lbs/hr		SOTR kg/hr	SOTR lbs/hr	Airflow scmm	Airflow scfm	Fine Bubble Diffusers Required
1	56.70	125.00		140.66	310.11	26.73	943.85	472
2	56.70	125.00		140.66	310.11	26.73	943.85	472
3	56.70	125.00		140.66	310.11	26.73	943.85	472
4	56.70	125.00		140.66	310.11	26.73	943.85	472
	226.80 kg/hr	500.00 lbs/hr		562.65 kg/hr	1,240.42 lbs/hr	106.92 scmm	3,775.40 scfm	1,888 units

**FINE BUBBLE DIFFUSER
UNIT AIRFLOW AND EFFICIENCY**

MODEL TFX-26

Headloss per diffuser	12.5	in.H ₂ O
Air flowrate per Diffuser	2.00	scfm
Diffuser Efficiency per foot depth	2.05%	
Total Diffuser efficiency (De)	31.78%	
Wastewater transfer efficiency	40%	

**GENERATED FROM
OXYGEN TRANSFER
CURVE & DEPTH**

0.0566 scmm

1 CUFT. OF AIR = 0.0174 LBS. O₂

**GENERATED FROM
ALPHA, BETA, THETA
PROCESS FACTORS**


Example Calculations
Evaluation for Fine Bubble Aeration System

FINE BUBBLE DIFFUSER SYSTEM
Design Check - Airflow Required for Complete Mixing based on Surface Area of Tank

Applied Design Unit Airflow Rate **0.200** scfm/sq.ft.
0.061 scmm/sq.m

Airflow Rate per Diffuser **2.000** scfm/diffuser
0.0566 scmm/diffuser

Recommended Minimum Design Values
 0.200 scfm/sq.ft. for MLSS up to 2500 mg/l
 0.240 scfm/sq.ft. for MLSS up to 3500 mg/l
 0.280 scfm/sq.ft. for MLSS up to 4500 mg/l



**UNIT DESIGN VALUES
TO OBTAIN SUFFICIENT
MIXING OF VOLUME**

Tank	Surface Area sq.ft.	Surface Area sq. meters	Airflow Rate Required		Quantity of Fine Bubble Diffusers Required
			scfm	scmm	
1	4,000	372	800.00	22.65	400
2	4,000	372	800.00	22.65	400
3	4,000	372	800.00	22.65	400
4	4,000	372	800.00	22.65	400

CHECK FOR MIXING REQUIRED

16,000.00
sq.ft.

1486.4
sq.m.

3,200.00
scfm

90.6
scmm

1,600
units

Note: If the Total Airflow Rate calculated on this sheet exceeds the Airflow Rate calculated to provide sufficient oxygen, then these values should be applied to ensure sufficient mixing is provided for the system.

DESIGN BY	Example Calculations Evaluation for Fine Bubble Aeration System	DESIGN BY
------------------	---	------------------

TANK CAPACITY	Oxygen Required for Volatile Solids Reduction	CURRENT LOAD
----------------------	---	---------------------

Waste Sludge Volume Determination		
Method 1		Method 2

<p>Volume of Tank <input style="width: 100px;" type="text" value="64,000"/> cu.ft.</p> <p>Volatile Solids Loading (0.1 - 0.3) <input style="width: 100px;" type="text" value="0.100"/> lbs./ cu.ft. - day</p> <p>Total Mass of Sludge in Influent <input style="width: 100px;" type="text" value="8,000"/> lbs./day Sludge</p>	<p>Waste Sludge Flowrate <input style="width: 100px;" type="text" value="90,000"/> gallons / day</p> <p>Percent Solids in WAS <input style="width: 100px;" type="text" value="1.00%"/></p> <p>Total Mass of Sludge in Influent <input style="width: 100px;" type="text" value="7499.7"/> lbs/day Sludge</p>
<p>Total Mass of Sludge in Influent (Maximum from Method 1 & Method 2) <input style="width: 100px;" type="text" value="8,000"/> lbs./day Sludge</p>	
<p>% Volatiles in Total Mass <input style="width: 100px;" type="text" value="80%"/></p>	
<p>Total Mass of Volatile Solids <input style="width: 100px;" type="text" value="6,400"/> lbs./day</p>	
<p>% Reduction of Volatiles through Digestion <input style="width: 100px;" type="text" value="30.00%"/> (30-40 % Standard)</p>	
<p>Total Volatiles Reduced <input style="width: 100px;" type="text" value="1,920"/> lbs./day</p>	
<p>Unit Rate for Oxygen Requirement <input style="width: 100px;" type="text" value="2.30"/> lbs.O2/ lbs. Volatile solids</p>	
<p>Mass of Oxygen Required <input style="width: 100px;" type="text" value="4,416"/> lbs.O2/day</p>	
<p>Actual Oxygen Transfer Rate (AOR) <input style="width: 100px;" type="text" value="184.00"/> lbs/hr</p>	
<p>Aeration Design Value</p>	
<p>AOR FOR DIGESTER DESIGN</p>	
<p>Check Hydraulic Retention Time <input style="width: 100px;" type="text" value="5.3195026"/> days</p>	
<p>(10-15 Waste activated sludge only) (12-18 Activated sludge without settling) (15-20 Primary + Secondary sludge)</p>	

**% VOLATILES
INFLUENT**

**% VOLATILES
REDUCED**

Example Calculations
Evaluation for Fine Bubble Aeration System

FINE BUBBLE DIFFUSER SYSTEM
APPLIED AIRFLOW BASED ON OXYGEN DEMAND REQUIREMENTS

Water Depth at Diffusers (DWD) = ft. m

Total System Operating Airflow (SCFM) = scfm scmm

Number of Operating Blowers =

SCFM

Airflow per Blower = scfm scmm

Airflow per Diffuser = scfm scmm

Inlet Blower Temperature (T) = F C

Site Barometric Pressure (BP) = psia Bar

Blower Efficiency Estimate =

Headloss - Hydrostatic = in. m

Headloss - Piping = in. m

Headloss - Diffusers = in. m

Total Headloss = in. m

Blower Gauge Pressure = psig Bar

Blower Discharge Atm Press = psia

**ADJUSTED AIRFLOW
REQUIRED DUE TO
SITE CONDITIONS**

R =

Mass Rate = lbs/min

Effective Blower Airflow (ICFM) = icfm icmm

ICFM

Individual Blower Output HP = HP kW

Individual Blower Brake HP = HP kW

Total Combined Output HP = HP kW

Total Combined Brake HP = HP kW

**BLOWER EFFICIENCY
ADJUSTMENT**